

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 3

Facility Information

RESULT: Satisfactory

Permit Number: 13-51-08195
Name of Facility: Coral Reef El.
Address: 7955 SW 152 Street
City, Zip: Miami 33157

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Schools
Owner: M-DCSB Food and Nutrition
Person In Charge: Christina Guerra Phone: 305-235-1464
PIC Email: clmguerra@dadeschools.net

Inspection Information

Purpose: Routine
Inspection Date: 3/19/2021

Begin Time: 09:50 AM
End Time: 11:30 AM

Additional Information

FEMALES 381
MALES 422

CENSUS 803

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN	11. Group Toilet Rooms	IN	21. Pest Control
IN 1. School Site	OUT	12. Toilet Facilities		SAFETY
IN 2. Playground, Equip & Athletic Fields*	OUT	13. Handwashing Facilities	IN	22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN	14. Soap Dispensers		DIAPER CHANGING STATION
BUILDING CONST/MAINT.	IN	15. Shower Facilities	NA	23. Sanitizers
IN 4. Construction	IN	16. Showers Water Temperatures	NA	24. Changing Station & Mats
OUT 5. Maintenance & Repair		WATER SUPPLY	NA	25. Hand Sink
IN 6. Lighting Standards	IN	17. Approved Source	NA	26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	IN	18. Drinking Fountains		ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation		LIQUID WASTE & WASTE WATER	NA	27. Animal Maintenance/Aggressive
OUT 9. Mechanical Ventilation	IN	19. Sewage Disposal		DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN	20. Solid Waste	NA	28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation		PEST CONTROL	NA	29. Other

Marking Key: **IN** = the act or item was observed to meet standards; **OUT** = the act or item was observed not to meet standards; **NO** = the act or item was not observed to be occurring at the time of inspection; **NA** = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

Client Signature:

Emailed to Christina Guerra 3-19-2021

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 3

General Comments

Satisfactory

Students bring their own bottle of water. Bottle filling stations were observed.
School is offering in-person and virtual learning.
Inspection was conducted during the COVID-19 pandemic.
Email to: Christina Guerra/3-19-2021

Email Address(es): clmguerra@dadeschools.net;
jaybolton@dadeschools.net;
jware@dadeschools.net;
ipalacio@dadeschools.net

Violations Comments

Violation #5. Maintenance & Repair

-Replace lightbulb in classroom #83 and #211.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #9. Mechanical Ventilation

-Repair mechanical extractors in the girls' restroom #209 and #258, in the boys' restroom #210 and #259, and in the restroom located inside of classroom #44 and #46.

CODE REFERENCE: 9. Mechanical Ventilation. 5(16)(a)2 SREF. Mechanical ventilation systems shall be maintained in an operable condition at all times. 5(16)(a)4 SREF. Exhaust systems from toilet rooms, custodial closets, shower and locker rooms, athletic equipment rooms, etc., shall be maintained in an operable condition at all times. 5(13)(g)1.d SREF. Toilet rooms shall have exhaust fans vented to the exterior. 5(16)(a)10 SREF. Stationary local sources producing air-borne particulates, heat, odors, fumes, spray, vapors, smoke or gases in such quantities as to be irritating or injurious to human health shall have an exhaust system to collect and remove the contaminants. Such exhaust shall discharge directly to the exterior of the building. 468.3.6.2 FBC and 468.3.6.3 FBC. Kiln rooms and areas shall be provided with adequate exhaust to dispel emitted heat to the exterior, and they shall not be connected to any other exhaust system. 5(16)(a)5 SREF. Science laboratory fume hoods and laboratory emergency fans shall be maintained in an operable condition. 468.3.6.4 FBC. HVAC systems in chemistry labs and science classrooms shall be designed and installed to ensure that chemicals originating from the space are not recirculated. 468.3.6.5 SREF. Rooms used for the storage, handling, and disposal of chemicals used in school, college, and university laboratories shall be vented to the exterior. The ventilation system shall not be connected to the air conditioning return air system.

Violation #12. Toilet Facilities

-Repair air-hand drier in the girls' restroom #258 and in the boys' restroom #259.

CODE REFERENCE: 12. Toilet Facilities. 5(16)(b)2.c SREF. Deodorizers shall not be used in toilet rooms. 5(10)(f) SREF. Toilet and bath accessories, including grab bars; toilet paper dispensers; paper towel dispensers or hot-air drying devices; napkin disposal units; shelving, and mirrors, where provided, shall be maintained in a safe and secure condition at all times. The use of common or public towels shall not be permitted. 5(13)(f)4 SREF. Toilet facilities shall have a nonslip, impervious floor, impervious base, and minimum four foot- high impervious wainscot. 5(13)(p)2 SREF. Each staff toilet room shall be provided with at least one water closet and one lavatory and shall be provided with hot and cold water at the lavatory. 5(14)(b)10.a SREF. Walls in toilet rooms shall be finished with impervious materials to a minimum height of four feet. Floor and base in individual or group toilet rooms shall be impervious. 468.3.5.4 FBC. The entry to each group toilet room shall be provided with a door, partition, or other shielding device to block from view the occupants in the toilet room. If a door is provided, it shall have a closer. 5(16)(b)1 SREF. Toilet facilities shall be maintained in a satisfactory state of repair at all times. 5(16)(b)2.a. SREF. Water closets, urinals, lavatories, faucets, flush valves, dispensers, partitions, lower half of walls, and floors shall be maintained in a clean & sanitary condition at all times.

Violation #13. Handwashing Facilities

-Repair dripping on faucet located in the girls' restroom #070.

CODE REFERENCE: 13. Handwashing Facilities. 5(13)(h)1 SREF. Hot and cold water shall be provided in toilet rooms at the lavatory. Hot water temperature shall not exceed 110°F. 468.3.5.7.1 FBC. Handwashing facilities shall be located within or adjoining each toilet room.

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



3 of 3

Inspection Conducted By: Lucia Gonzalez Melendez (913031)
Inspector Contact Number: Work: (305) 623-3500 ex.
Print Client Name: Coral Reef El.
Date: 3/19/2021

Inspector Signature:

Handwritten signature of Lucia Gonzalez Melendez.

Client Signature:

Handwritten signature of Christina Guerra dated 3-19-2021.